

Subtype LW 101

Certificate Holder	ait-deutschland GmbH
Address	Industriestr. 3
ZIP	95359
City	Kasendorf
Country	DE
Certification Body	BRE Global Limited
Subtype title	LW 101
Registration number	041-K001-36
Heat Pump Type	Outdoor Air/Water
Refrigerant	R407c
Mass of Refrigerant	4.8 kg
Certification Date	08.10.2019

Model LW 101

Model name	LW 101
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.40 kW	10.27 kW
El input	2.49 kW	3.71 kW
COP	4.18	2.64

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	149 %	121 %
Prated	9.90 kW	9.35 kW
SCOP	3.81	3.11
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.53 kW	6.98 kW
COP Tj = -7°C	2.97	2.03
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	9.54 kW	9.41 kW
COP Tj = +2°C	3.78	3.11
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	10.43 kW	10.40 kW
COP Tj = +7°C	4.69	4.04
Cdh Tj = +7 °C	1.00	1.00

Pdh Tj = 12°C	12.19 kW	12.17 kW
COP Tj = 12°C	5.15	5.02
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	8.00 kW	7.55 kW
COP Tj = Tbiv	3.19	2.25
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.84 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.70	1.79
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.06 kW	3.08 kW
Annual energy consumption Qhe	5367 kWh	6216 kWh

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	132 %	108 %
Prated	8.82 kW	8.22 kW
SCOP	3.38	2.77
Tbiv	-12 °C	-12 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.62 kW	7.23 kW
COP Tj = -7°C	3.18	2.37
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	9.57 kW	9.48 kW
COP Tj = +2°C	3.92	3.40
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	10.44 kW	10.42 kW
COP Tj = +7°C	4.83	4.44
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	12.18 kW	12.20 kW
COP Tj = 12°C	5.00	5.18
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.50 kW	6.06 kW
COP Tj = Tbiv	2.77	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.66 kW	4.24 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.99	1.34
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W

PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	8.82 kW	8.22 kW
Annual energy consumption Q _{he}	6437 kWh	7306 kWh
P _{dh} T _j = -15 °C (if TOL	5.80	5.37
COP T _j = -15 °C (if TOL	2.47	1.72
C _{dh} T _j = -15 °C	1.00	1.00

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	179 %	145 %
Prated	11.53 kW	11.30 kW
SCOP	4.56	3.71
T _{biv}	4 °C	4 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2 °C	9.50 kW	9.23 kW
COP T _j = +2 °C	3.56	2.52
C _{dh} T _j = +2 °C	1.00	1.00
P _{dh} T _j = +7 °C	10.42 kW	10.33 kW
COP T _j = +7 °C	4.46	3.27
C _{dh} T _j = +7 °C	1.00	1.00
P _{dh} T _j = 12 °C	12.17 kW	12.10 kW
COP T _j = 12 °C	5.08	4.61
C _{dh} T _j = +12 °C	1.00	1.00
P _{dh} T _j = T _{biv}	9.88 kW	9.68 kW
COP T _j = T _{biv}	3.94	2.78
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	9.50 kW	9.23 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.56	2.52
WTOL	65 °C	65 °C
P _{off}	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.03 kW	2.07 kW
Annual energy consumption Q _{he}	3376 kWh	4069 kWh

Model LW 101A

Model name	LW 101A
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.40 kW	10.27 kW
El input	2.49 kW	3.71 kW
COP	4.18	2.64

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	50 dB(A)	50 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	149 %	121 %
Prated	9.90 kW	9.35 kW
SCOP	3.81	3.11
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.53 kW	6.98 kW
COP Tj = -7°C	2.97	2.03
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	9.54 kW	9.41 kW
COP Tj = +2°C	3.78	3.11
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	10.43 kW	10.40 kW
COP Tj = +7°C	4.69	4.04

Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	12.19 kW	12.17 kW
COP Tj = 12°C	5.15	5.02
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	8.00 kW	7.55 kW
COP Tj = Tbiv	3.19	2.25
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.84 kW	6.27 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.70	1.79
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.06 kW	3.08 kW
Annual energy consumption Qhe	5367 kWh	6216 kWh

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	132 %	108 %
Prated	8.82 kW	8.22 kW
SCOP	3.38	2.77
Tbiv	-12 °C	-12 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.62 kW	7.23 kW
COP Tj = -7°C	3.18	2.37
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	9.57 kW	9.48 kW
COP Tj = +2°C	3.92	3.40
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	10.44 kW	10.42 kW
COP Tj = +7°C	4.83	4.44
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	12.18 kW	12.20 kW
COP Tj = 12°C	5.00	5.18
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	6.50 kW	6.06 kW
COP Tj = Tbiv	2.77	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.66 kW	4.24 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.99	1.34
WTOL	65 °C	65 °C
Poff	10 W	10 W

PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	8.82 kW	8.22 kW
Annual energy consumption Q _{he}	6437 kWh	7306 kWh
P _{dh} T _j = -15 °C (if TOL	5.80	5.37
COP T _j = -15 °C (if TOL	2.47	1.72
C _{dh} T _j = -15 °C	1.00	1.00

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	179 %	145 %
Prated	11.53 kW	11.30 kW
SCOP	4.56	3.71
T _{biv}	4 °C	4 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2 °C	9.50 kW	9.23 kW
COP T _j = +2 °C	3.56	2.52
C _{dh} T _j = +2 °C	1.00	1.00
P _{dh} T _j = +7 °C	10.42 kW	10.33 kW
COP T _j = +7 °C	4.46	3.27
C _{dh} T _j = +7 °C	1.00	1.00
P _{dh} T _j = 12 °C	12.17 kW	12.10 kW
COP T _j = 12 °C	5.08	4.61
C _{dh} T _j = +12 °C	1.00	1.00
P _{dh} T _j = T _{biv}	9.88 kW	9.68 kW
COP T _j = T _{biv}	3.94	2.78
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	9.50 kW	9.23 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.56	2.52
WTOL	65 °C	65 °C
P _{off}	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.03 kW	2.07 kW
Annual energy consumption Q _{he}	3376 kWh	4069 kWh