

Subtype LW 140

Certificate Holder	ait-deutschland GmbH
Address	Industriestr. 3
ZIP	95359
City	Kasendorf
Country	DE
Certification Body	BRE Global Limited
Subtype title	LW 140
Registration number	041-K001-38
Heat Pump Type	Outdoor Air/Water
Refrigerant	R407c
Mass of Refrigerant	10.2 kg
Certification Date	08.10.2019

Model LW 140 (L)

Model name	LW 140 (L)
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	14.38 kW	13.74 kW
El input	3.26 kW	4.70 kW
COP	4.30	2.83

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	157 %	125 %
Prated	14.43 kW	13.71 kW
SCOP	4.00	3.20
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.00 kW	10.40 kW
COP Tj = -7°C	3.13	2.16
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	13.90 kW	13.49 kW
COP Tj = +2°C	3.94	3.10
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	14.53 kW	14.35 kW
COP Tj = +7°C	4.94	4.28
Cdh Tj = +7 °C	1.00	1.00

Pdh Tj = 12°C	16.37 kW	16.34 kW
COP Tj = 12°C	5.43	5.27
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	11.66 kW	11.07 kW
COP Tj = Tbiv	3.34	2.34
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.15 kW	9.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.87	1.96
WTOL	50 °C	50 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.28 kW	4.13 kW
Annual energy consumption Qhe	7447 kWh	8842 kWh

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	140 %	115 %
Prated	13.15 kW	12.60 kW
SCOP	3.58	2.95
Tbiv	-12 °C	-12 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	11.09 kW	10.66 kW
COP Tj = -7°C	3.35	2.51
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	13.99 kW	13.70 kW
COP Tj = +2°C	4.14	3.47
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	14.57 kW	14.47 kW
COP Tj = +7°C	5.09	4.70
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	16.36 kW	16.40 kW
COP Tj = 12°C	5.31	5.49
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	9.69 kW	9.29 kW
COP Tj = Tbiv	2.95	2.15
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.43 kW	7.71 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.24	1.78
WTOL	50 °C	50 °C
Poff	10 W	10 W
PTO	10 W	10 W

PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	13.15 kW	12.60 kW
Annual energy consumption Q _{he}	9044 kWh	10533 kWh
P _{dh} T _j = -15 °C (if TOL	8.83	8.49
COP T _j = -15 °C (if TOL	2.68	1.96
C _{dh} T _j = -15 °C	1.00	1.00

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	190 %	152 %
Prated	16.43 kW	15.64 kW
SCOP	4.82	3.88
T _{biv}	4 °C	4 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2 °C	13.79 kW	12.95 kW
COP T _j = +2 °C	3.66	2.38
C _{dh} T _j = +2 °C	1.00	1.00
P _{dh} T _j = +7 °C	14.46 kW	14.03 kW
COP T _j = +7 °C	4.71	3.46
C _{dh} T _j = +7 °C	1.00	1.00
P _{dh} T _j = 12 °C	16.32 kW	16.17 kW
COP T _j = 12 °C	5.33	4.80
C _{dh} T _j = +12 °C	1.00	1.00
P _{dh} T _j = T _{biv}	14.08 kW	13.40 kW
COP T _j = T _{biv}	4.10	2.76
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	13.79 kW	12.95 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.66	2.38
WTOL	50 °C	50 °C
P _{off}	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.64 kW	2.69 kW
Annual energy consumption Q _{he}	4553 kWh	5391 kWh

Model LW 140A

Model name	LW 140A
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	14.38 kW	13.74 kW
El input	3.26 kW	4.70 kW
COP	4.30	2.83

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	58 dB(A)	58 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	157 %	125 %
Prated	14.43 kW	13.71 kW
SCOP	4.00	3.20
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.00 kW	10.40 kW
COP Tj = -7°C	3.13	2.16
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	13.90 kW	13.49 kW
COP Tj = +2°C	3.94	3.10
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	14.53 kW	14.35 kW
COP Tj = +7°C	4.94	4.28

Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	16.37 kW	16.34 kW
COP Tj = 12°C	5.43	5.27
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	11.66 kW	11.07 kW
COP Tj = Tbiv	3.34	2.34
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.15 kW	9.58 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.87	1.96
WTOL	50 °C	50 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.28 kW	4.13 kW
Annual energy consumption Qhe	7447 kWh	8842 kWh

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	140 %	115 %
Prated	13.15 kW	12.60 kW
SCOP	3.58	2.95
Tbiv	-12 °C	-12 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	11.09 kW	10.66 kW
COP Tj = -7°C	3.35	2.51
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	13.99 kW	13.70 kW
COP Tj = +2°C	4.14	3.47
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	14.57 kW	14.47 kW
COP Tj = +7°C	5.09	4.70
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	16.36 kW	16.40 kW
COP Tj = 12°C	5.31	5.49
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	9.69 kW	9.29 kW
COP Tj = Tbiv	2.95	2.15
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.43 kW	7.71 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.24	1.78
WTOL	50 °C	50 °C
Poff	10 W	10 W

PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	13.15 kW	12.60 kW
Annual energy consumption Q _{he}	9044 kWh	10533 kWh
P _{dh} T _j = -15 °C (if TOL	8.83	8.49
COP T _j = -15 °C (if TOL	2.68	1.96
C _{dh} T _j = -15 °C	1.00	1.00

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	190 %	152 %
Prated	16.43 kW	15.64 kW
SCOP	4.82	3.88
T _{biv}	4 °C	4 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2 °C	13.79 kW	12.95 kW
COP T _j = +2 °C	3.66	2.38
C _{dh} T _j = +2 °C	1.00	1.00
P _{dh} T _j = +7 °C	14.46 kW	14.03 kW
COP T _j = +7 °C	4.71	3.46
C _{dh} T _j = +7 °C	1.00	1.00
P _{dh} T _j = 12 °C	16.32 kW	16.17 kW
COP T _j = 12 °C	5.33	4.80
C _{dh} T _j = +12 °C	1.00	1.00
P _{dh} T _j = T _{biv}	14.08 kW	13.40 kW
COP T _j = T _{biv}	4.10	2.76
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	13.79 kW	12.95 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.66	2.38
WTOL	50 °C	50 °C
P _{off}	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.64 kW	2.69 kW
Annual energy consumption Q _{he}	4553 kWh	5391 kWh