

| Subtype AQUA PLUS SWAN-2 190S | | |
|-------------------------------|--|--|
| Certificate Holder | Clivet s.p.a. | |
| Address | Via camp lonc 25 c.ap. | |
| ZIP | I-32032 | |
| City | z.i. Villapaiera - Feltre (BL) | |
| Country | IT | |
| Certification Body | ICIM S.p.A. | |
| Subtype title | AQUA PLUS SWAN-2 190S | |
| Registration number | ICIM-PDC-000030 | |
| Heat Pump Type | Heat Pump for Domestic Hot Water (DHW) | |
| Refrigerant | R134a | |
| Mass of Refrigerant | 1.1 kg | |
| Certification Date | 02.05.2019 | |
| Testing basis | HP KEYMARK certification scheme rules rev. no. 4 | |



| Model SWAN-2 190S | |
|---|---------------|
| Model name | SWAN-2 190S |
| Application | Heating + DHW |
| Units | Indoor |
| Climate zone (for heating) | n/a |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |
| General data | |
| Power supply | 1x230V 50Hz |
| Off-peak product | No |
| Heat Pump for Domestic Hot Water (DHW) EN 16147 Operating test | |
| Temperature operating range | 2 |
| Safety devices checking test | 2 |
| Condensate draining | 2 |
| EN 12102-2 Average Climate | |
| Sound power level indoor | 51 dB(A) |
| EN 16147 Average Climate | |
| Declared load profile | L |
| Efficiency ηDHW | 115 % |
| COP | 2.76 |
| Heating up time | 7:01 h:min |
| Standby power input | 26.3 W |
| Reference hot water temperature | 53.8 °C |
| Mixed water at 40°C | 234 l |