

Subtype Grant Aerona3 HPID17R32

Certificate Holder	Grant Engineering (Ireland) ULC
Address	Barrack St
ZIP	R42 D788
City	Ballinree, Birr
Country	IE
Certification Body	BRE Global Limited
Subtype title	Grant Aerona3 HPID17R32
Registration number	041-K005-04
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	2.8 kg
Certification Date	01.03.2022
Testing basis	Heat Pump Keymark Scheme Rules Rev 09

Model HPID17R32		
Model name	HPID17R32	
Application	Heating + DHW + low temp	
Units	Outdoor	
Climate zone (for heating)	n/a	
Cooling mode application (optional)	n/a	
Any additional heat sources	n/a	
General data		
Power supply	1x230V 50Hz	
Off-peak product	n/a	
Outdoor Air/Water		
EN 16147 Average Climate		
Declared load profile	L	
Efficiency η_{DHW}	99 %	
COP	2.4	
Heating up time	00:49 h:min	
Standby power input	27.5 W	
Reference hot water temperature	49.42 °C	
Mixed water at 40°C	279.21 l	
EN 14511-4 Heating		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	
EN 14511-2 Heating		
	Low temperature	Medium temperature
Heat output	18 kW	15.3 kW
El input	3.77 kW	4.86 kW
COP	4.79	3.15
EN 12102-1 Average Climate		
	Low temperature	Medium temperature
Sound power level outdoor	61.6 dB(A)	61.6 dB(A)
EN 14825 Average Climate		
	Low temperature	Medium temperature
η_s	181 %	142 %
Prated	12.80 kW	12.20 kW
SCOP	4.61	3.64
Tbiv	-9 °C	-8 °C

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.00 kW	12.80 kW
COP Tj = -7°C	3.06	2.34
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	7.70 kW	7.43 kW
COP Tj = +2°C	4.61	3.61
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	9.20 kW	9.11 kW
COP Tj = +7°C	6.75	5.21
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.20 kW	6.10 kW
COP Tj = 12°C	9.64	8.12
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	11.64 kW	10.76 kW
COP Tj = Tbiv	3.08	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.40 kW	9.57 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.24	2.15
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	60 °C	60 °C
Poff	100 W	100 W
PTO	40 W	40 W
PSB	100 W	100 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.40 kW	2.63 kW
Annual energy consumption Qhe	5731 kWh	6931 kWh