Subtype 31. Yutaki S (N1) & S Combi (NW1) 220L 4HP R410A (3ph)	
Certificate Holder	Bosch Home Comfort Barcelona S.A.U.
Address	Ronda Shimizu, 1. Pol. Ind. Can Torrella
ZIP	08233
City	Vacarisses, Barcelona
Country	ES
Certification Body	BRE
Subtype title	31. Yutaki S (N1) & S Combi (NW1) 220L 4HP R410A (3ph)
Registration number	041-K002-52
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	3.3 kg
Certification Date	08.02.2022
Testing basis	Heat Pump Keymark Scheme Rules Rev 09
Testing laboratory	Centro de Ensayos, Innovación y Servicios (CEIS), ES

This information was generated by the HP KEYMARK database on 16.11.2026

Model 03. RAS-4WHNPE RWD-4.0NW1E-220S - Heating Only

Model name	03. RAS-4WHNPE RWD-4.0NW1E-220S - Heating Only
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency ηDHW	127 %
COP	3.10
Heating up time	1:05 h:min
Standby power input	34.0 W
Reference hot water temperature	52.6 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
ηs	180 %	135 %
Prated	11.00 kW	10.00 kW

This information was generated by the HP KEYMARK database on 16.11.2026

SCOP	4.58	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.45 kW	8.60 kW
COP Tj = -7°C	3.05	1.80
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.75 kW	5.23 kW
COP Tj = +2°C	4.50	3.60
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.70 kW	3.52 kW
COP Tj = +7°C	6.00	4.80
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.50	5.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.45 kW	8.60 kW
COP Tj = Tbiv	3.05	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.60 kW
Annual energy consumption Qhe	4823 kWh	5837 kWh

This information was generated by the HP KEYMARK database on 16.11.2026

Model 04. RAS-4WHNPE RWD-4.0NW1E-220S - with cooling kit

Model name	04. RAS-4WHNPE RWD-4.0NW1E-220S - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	n/a
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency ηDHW	127 %
COP	3.10
Heating up time	1:05 h:min
Standby power input	34.0 W
Reference hot water temperature	52.6 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	1.87 kW	2.31 kW
Cooling capacity	7.20	10.40
EER	3.84	4.50

EN 12102-1 | Average Climate

	Low temperature	Medium temperature

This information was generated by the HP KEYMARK database on 16.11.2026

Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
ηs	183 %	136 %
Prated	11.00 kW	10.00 kW
SCOP	4.64	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.45 kW	8.60 kW
COP Tj = -7°C	3.05	1.80
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.75 kW	5.23 kW
COP Tj = +2°C	4.50	3.60
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.70 kW	3.52 kW
COP Tj = +7°C	6.00	4.80
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.50	5.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.45 kW	8.60 kW
COP Tj = Tbiv	3.05	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.60 kW
Annual energy consumption Qhe	4753 kWh	5767 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	7.20 kW	10.40 kW
SEER	5.00	6.22
Pdc Tj = 35°C	7.20 kW	10.40 kW
EER Tj = 35°C	3.84	4.50
Pdc Tj = 30°C	5.30 kW	7.66 kW

This information was generated by the HP KEYMARK database on 16.11.2026

EER Tj = 30°C	4.60	6.30
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	3.50 kW	4.93 kW
EER Tj = 25°C	5.80	7.20
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	3.60 kW	5.10 kW
EER Tj = 20°C	7.50	8.20
Cdc Tj = 20 °C	0.900	0.900
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Annual energy consumption Qce	504 kWh	585 kWh

This information was generated by the HP KEYMARK database on 16.11.2026

Model 05. RAS-4WHNPE RWD-4.0NW1E-220S-K – UK Version - Heating Only	
Model name	05. RAS-4WHNPE RWD-4.0NW1E-220S-K – UK Version - Heating Only
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data	
Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water EN 16147 | Average Climate	
Declared load profile	L
Efficiency ηDHW	127 %
COP	3.10
Heating up time	1:05 h:min
Standby power input	34.0 W
Reference hot water temperature	52.6 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating		
	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00

EN 12102-1 | Average Climate		
	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate		
	Low temperature	Medium temperature
ηs	180 %	135 %
Prated	11.00 kW	10.00 kW

This information was generated by the HP KEYMARK database on 16.11.2026

SCOP	4.58	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.45 kW	8.60 kW
COP Tj = -7°C	3.05	1.80
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.75 kW	5.23 kW
COP Tj = +2°C	4.50	3.60
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.70 kW	3.52 kW
COP Tj = +7°C	6.00	4.80
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.50	5.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.45 kW	8.60 kW
COP Tj = Tbiv	3.05	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.60 kW
Annual energy consumption Qhe	4823 kWh	5837 kWh

This information was generated by the HP KEYMARK database on 16.11.2026

Model 06. RAS-4WHNPE RWD-4.0NW1E-220S-K – UK Version - with cooling kit

Model name	06. RAS-4WHNPE RWD-4.0NW1E-220S-K – UK Version - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency ηDHW	127 %
COP	3.10
Heating up time	1:05 h:min
Standby power input	34.0 W
Reference hot water temperature	52.6 °C
Mixed water at 40°C	288 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	1.87 kW	2.31 kW
Cooling capacity	7.20	10.40
EER	3.84	4.50

EN 12102-1 | Average Climate

	Low temperature	Medium temperature

This information was generated by the HP KEYMARK database on 16.11.2026

Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
ηs	183 %	136 %
Prated	11.00 kW	10.00 kW
SCOP	4.64	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.45 kW	8.60 kW
COP Tj = -7°C	3.05	1.80
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.75 kW	5.23 kW
COP Tj = +2°C	4.50	3.60
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.70 kW	3.52 kW
COP Tj = +7°C	6.00	4.80
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.50	5.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.45 kW	8.60 kW
COP Tj = Tbiv	3.05	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.60 kW
Annual energy consumption Qhe	4753 kWh	5767 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	7.20 kW	10.40 kW
SEER	5.00	6.22
Pdc Tj = 35°C	7.20 kW	10.40 kW
EER Tj = 35°C	3.84	4.50
Pdc Tj = 30°C	5.30 kW	7.66 kW

This information was generated by the HP KEYMARK database on 16.11.2026

EER Tj = 30°C	4.60	6.30
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	3.50 kW	4.93 kW
EER Tj = 25°C	5.80	7.20
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	3.60 kW	5.10 kW
EER Tj = 20°C	7.50	8.20
Cdc Tj = 20 °C	0.900	0.900
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Annual energy consumption Qce	504 kWh	585 kWh

This information was generated by the HP KEYMARK database on 16.11.2026

Model 01. RAS-4WHNPE RWM-4.0N1E - Heating Only

Model name	01. RAS-4WHNPE RWM-4.0N1E - Heating Only
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
ηs	180 %	135 %
Prated	11.00 kW	10.00 kW
SCOP	4.58	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.45 kW	8.60 kW
COP Tj = -7°C	3.05	1.80
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.75 kW	5.23 kW
COP Tj = +2°C	4.50	3.60
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.70 kW	3.52 kW

COP Tj = +7°C	6.00	4.80
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.50	5.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.45 kW	8.60 kW
COP Tj = Tbiv	3.05	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.60 kW
Annual energy consumption Qhe	4823 kWh	5837 kWh

This information was generated by the HP KEYMARK database on 16.11.2026

Model 02. RAS-4WHNPE RWM-4.0N1E - with cooling kit

Model name	02. RAS-4WHNPE RWM-4.0N1E - with cooling kit
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	1.87 kW	2.31 kW
Cooling capacity	7.20	10.40
EER	3.84	4.50

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
ηs	183 %	136 %
Prated	11.00 kW	10.00 kW
SCOP	4.64	3.44
Tbiv	-7 °C	-7 °C

This information was generated by the HP KEYMARK database on 16.11.2026

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.45 kW	8.60 kW
COP Tj = -7°C	3.05	1.80
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.75 kW	5.23 kW
COP Tj = +2°C	4.50	3.60
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.70 kW	3.52 kW
COP Tj = +7°C	6.00	4.80
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.50	5.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.45 kW	8.60 kW
COP Tj = Tbiv	3.05	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.60 kW
Annual energy consumption Qhe	4753 kWh	5767 kWh

EN 14825 | Cooling		
	+7°C/+12°C	+18°C/+23°C
Pdesignc	7.20 kW	10.40 kW
SEER	5.00	6.22
Pdc Tj = 35°C	7.20 kW	10.40 kW
EER Tj = 35°C	3.84	4.50
Pdc Tj = 30°C	5.30 kW	7.66 kW
EER Tj = 30°C	4.60	6.30
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	3.50 kW	4.93 kW
EER Tj = 25°C	5.80	7.20
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	3.60 kW	5.10 kW
EER Tj = 20°C	7.50	8.20
Cdc Tj = 20 °C	0.900	0.900
Poff	19 W	19 W

This information was generated by the HP KEYMARK database on 16.11.2026

PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Annual energy consumption Qce	504 kWh	585 kWh

This information was generated by the HP KEYMARK database on 16.11.2026