

## Subtype VERSI 0209

|                     |                                                       |
|---------------------|-------------------------------------------------------|
| Certificate Holder  | KRONOTERM d.o.o.                                      |
| Address             | Trnava 5e                                             |
| ZIP                 | 3303                                                  |
| City                | Gomilsko                                              |
| Country             | SI                                                    |
| Certification Body  | DIN CERTCO Gesellschaft für Konformitätsbewertung mbH |
| Subtype title       | VERSI 0209                                            |
| Registration number | 011-1W0519                                            |
| Heat Pump Type      | Outdoor Air/Water                                     |
| Refrigerant         | R452B                                                 |
| Mass of Refrigerant | 1.5 kg                                                |
| Certification Date  | 18.01.2022                                            |
| Testing basis       | HP KEYMARK certification scheme rules rev. 9          |

## Model VERSI-I 0209-K1 HT / HK UF E

|                                     |                              |
|-------------------------------------|------------------------------|
| Model name                          | VERSI-I 0209-K1 HT / HK UF E |
| Application                         | Heating (medium temp)        |
| Units                               | Indoor, Outdoor              |
| Climate zone (for heating)          | Colder, Warmer               |
| Reversibility                       | Yes                          |
| Cooling mode application (optional) | n/a                          |
| Any additional heat sources         | n/a                          |

## General data

|                  |             |
|------------------|-------------|
| Power supply     | 1x230V 50Hz |
| Off-peak product | n/a         |

## Outdoor Air/Water

## EN 14511-4 | Heating

|                                            |        |
|--------------------------------------------|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure              | passed |
| Defrost test                               | passed |
| Starting and operating test                | passed |

## EN 14511-2 | Heating

|             | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 6.13 kW         | 6.09 kW            |
| El input    | 1.28 kW         | 1.95 kW            |
| COP         | 4.80            | 3.13               |

## EN 12102-1 | Average Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor  | 36 dB(A)        | 42 dB(A)           |
| Sound power level outdoor | 45 dB(A)        | 45 dB(A)           |

## EN 14825 | Average Climate

|                | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| $\eta_s$       | 186 %           | 141 %              |
| Prated         | 6.50 kW         | 6.10 kW            |
| SCOP           | 4.84            | 3.66               |
| Tbiv           | -10 °C          | -10 °C             |
| TOL            | -10 °C          | -10 °C             |
| Pdh Tj = -7°C  | 5.76 kW         | 5.46 kW            |
| COP Tj = -7°C  | 3.05            | 2.32               |
| Cdh Tj = -7 °C | 1.000           | 1.000              |
| Pdh Tj = +2°C  | 3.57 kW         | 3.30 kW            |
| COP Tj = +2°C  | 5.01            | 3.71               |
| Cdh Tj = +2 °C | 0.990           | 0.990              |

|                                                     |             |             |
|-----------------------------------------------------|-------------|-------------|
| Pdh Tj = +7°C                                       | 2.45 kW     | 2.20 kW     |
| COP Tj = +7°C                                       | 5.79        | 4.30        |
| Cdh Tj = +7 °C                                      | 0.980       | 0.990       |
| Pdh Tj = 12°C                                       | 2.72 kW     | 2.53 kW     |
| COP Tj = 12°C                                       | 6.62        | 5.82        |
| Cdh Tj = +12 °C                                     | 0.980       | 0.980       |
| Pdh Tj = Tbiv                                       | 6.20 kW     | 6.07 kW     |
| COP Tj = Tbiv                                       | 2.78        | 2.16        |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 6.20 kW     | 6.07 kW     |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.78        | 2.16        |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000       | 1.000       |
| WTOL                                                | 67 °C       | 67 °C       |
| Poff                                                | 8 W         | 8 W         |
| PTO                                                 | 8 W         | 8 W         |
| PSB                                                 | 8 W         | 8 W         |
| PCK                                                 | 8 W         | 8 W         |
| Supplementary Heater: Type of energy input          | Electricity | Electricity |
| Supplementary Heater: PSUP                          | 0.30 kW     | 0.03 kW     |
| Annual energy consumption Qhe                       | 2773 kWh    | 3441 kWh    |

#### EN 12102-1 | Colder Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor  | 36 dB(A)        | 42 dB(A)           |
| Sound power level outdoor | 45 dB(A)        | 45 dB(A)           |

#### EN 14825 | Colder Climate

|                | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| ηs             | 169 %           | 119 %              |
| Prated         | 7.00 kW         | 6.40 kW            |
| SCOP           | 4.31            | 3.17               |
| Tbiv           | -17 °C          | -17 °C             |
| TOL            | -22 °C          | -17 °C             |
| Pdh Tj = -7°C  | 4.38 kW         | 3.98 kW            |
| COP Tj = -7°C  | 3.66            | 2.82               |
| Cdh Tj = -7 °C | 0.990           | 1.000              |
| Pdh Tj = +2°C  | 2.67 kW         | 2.35 kW            |
| COP Tj = +2°C  | 5.22            | 3.63               |
| Cdh Tj = +2 °C | 0.990           | 0.990              |
| Pdh Tj = +7°C  | 2.48 kW         | 2.30 kW            |
| COP Tj = +7°C  | 6.38            | 4.92               |
| Cdh Tj = +7 °C | 0.980           | 0.980              |
| Pdh Tj = 12°C  | 2.72 kW         | 2.70 kW            |
| COP Tj = 12°C  | 6.62            | 6.80               |

|                                                     |             |             |
|-----------------------------------------------------|-------------|-------------|
| Cdh Tj = +12 °C                                     | 0.980       | 0.980       |
| Pdh Tj = Tbiv                                       | 6.15 kW     | 5.59 kW     |
| COP Tj = Tbiv                                       | 2.47        | 1.94        |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 5.51 kW     | 5.59 kW     |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.20        | 1.94        |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000       | 1.000       |
| WTOL                                                | 67 °C       | 67 °C       |
| Poff                                                | 8 W         | 8 W         |
| PTO                                                 | 8 W         | 8 W         |
| PSB                                                 | 8 W         | 8 W         |
| PCK                                                 | 8 W         | 8 W         |
| Supplementary Heater: Type of energy input          | Electricity | Electricity |
| Supplementary Heater: PSUP                          | 1.49 kW     | 6.40 kW     |
| Annual energy consumption Qhe                       | 4003 kWh    | 4984 kWh    |
| Pdh Tj = -15°C (if TOL                              | 5.55        | 5.22        |
| COP Tj = -15°C (if TOL                              | 2.48        | 1.90        |
| Cdh Tj = -15 °C                                     | 1.000       | 1.000       |

#### EN 12102-1 | Warmer Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor  | 36 dB(A)        | 42 dB(A)           |
| Sound power level outdoor | 45 dB(A)        | 45 dB(A)           |

#### EN 14825 | Warmer Climate

|                                                     | Low temperature | Medium temperature |
|-----------------------------------------------------|-----------------|--------------------|
| $\eta_s$                                            | 239 %           | 179 %              |
| Prated                                              | 6.00 kW         | 5.90 kW            |
| SCOP                                                | 6.10            | 4.57               |
| Tbiv                                                | 2 °C            | 2 °C               |
| TOL                                                 | 2 °C            | 2 °C               |
| Pdh Tj = +2°C                                       | 5.68 kW         | 5.58 kW            |
| COP Tj = +2°C                                       | 3.52            | 2.57               |
| Cdh Tj = +2 °C                                      | 1.000           | 1.000              |
| Pdh Tj = +7°C                                       | 4.19 kW         | 3.93 kW            |
| COP Tj = +7°C                                       | 5.85            | 4.03               |
| Cdh Tj = +7 °C                                      | 0.990           | 0.990              |
| Pdh Tj = 12°C                                       | 2.69 kW         | 2.59 kW            |
| COP Tj = 12°C                                       | 6.91            | 5.61               |
| Cdh Tj = +12 °C                                     | 0.980           | 0.980              |
| Pdh Tj = Tbiv                                       | 5.68 kW         | 5.58 kW            |
| COP Tj = Tbiv                                       | 3.52            | 2.57               |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 5.68 kW         | 5.58 kW            |

|                                                                         |             |             |
|-------------------------------------------------------------------------|-------------|-------------|
| COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$       | 3.52        | 2.57        |
| $C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$ | 1.000       | 1.000       |
| WTOL                                                                    | 67 °C       | 67 °C       |
| P <sub>off</sub>                                                        | 8 W         | 8 W         |
| PTO                                                                     | 8 W         | 8 W         |
| PSB                                                                     | 8 W         | 8 W         |
| PCK                                                                     | 8 W         | 8 W         |
| Supplementary Heater: Type of energy input                              | Electricity | Electricity |
| Supplementary Heater: PSUP                                              | 0.32 kW     | 0.32 kW     |
| Annual energy consumption Q <sub>he</sub>                               | 1326 kWh    | 1737 kWh    |

## Model VERSI-X 0209-K1 HT / HK 1F

|                                     |                            |
|-------------------------------------|----------------------------|
| Model name                          | VERSI-X 0209-K1 HT / HK 1F |
| Application                         | Heating (medium temp)      |
| Units                               | Indoor, Outdoor            |
| Climate zone (for heating)          | Colder, Warmer             |
| Reversibility                       | Yes                        |
| Cooling mode application (optional) | n/a                        |
| Any additional heat sources         | n/a                        |

## General data

|                  |             |
|------------------|-------------|
| Power supply     | 1x230V 50Hz |
| Off-peak product | n/a         |

## Outdoor Air/Water

### EN 14511-4 | Heating

|                                            |        |
|--------------------------------------------|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure              | passed |
| Defrost test                               | passed |
| Starting and operating test                | passed |

### EN 14511-2 | Heating

|             | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 6.13 kW         | 6.09 kW            |
| El input    | 1.28 kW         | 1.95 kW            |
| COP         | 4.80            | 3.13               |

### EN 12102-1 | Average Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor  | 36 dB(A)        | 42 dB(A)           |
| Sound power level outdoor | 45 dB(A)        | 45 dB(A)           |

### EN 14825 | Average Climate

|                | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| $\eta_s$       | 186 %           | 141 %              |
| Prated         | 6.50 kW         | 6.10 kW            |
| SCOP           | 4.84            | 3.66               |
| Tbiv           | -10 °C          | -10 °C             |
| TOL            | -10 °C          | -10 °C             |
| Pdh Tj = -7°C  | 5.76 kW         | 5.46 kW            |
| COP Tj = -7°C  | 3.05            | 2.32               |
| Cdh Tj = -7 °C | 1.000           | 1.000              |
| Pdh Tj = +2°C  | 3.57 kW         | 3.30 kW            |
| COP Tj = +2°C  | 5.01            | 3.71               |
| Cdh Tj = +2 °C | 0.990           | 0.990              |

|                                                     |             |             |
|-----------------------------------------------------|-------------|-------------|
| Pdh Tj = +7°C                                       | 2.45 kW     | 2.20 kW     |
| COP Tj = +7°C                                       | 5.79        | 4.30        |
| Cdh Tj = +7 °C                                      | 0.980       | 0.980       |
| Pdh Tj = 12°C                                       | 2.72 kW     | 2.53 kW     |
| COP Tj = 12°C                                       | 6.62        | 5.82        |
| Cdh Tj = +12 °C                                     | 0.980       | 0.980       |
| Pdh Tj = Tbiv                                       | 6.20 kW     | 6.07 kW     |
| COP Tj = Tbiv                                       | 2.78        | 2.16        |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 6.20 kW     | 6.07 kW     |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.78        | 2.16        |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000       | 1.000       |
| WTOL                                                | 67 °C       | 67 °C       |
| Poff                                                | 8 W         | 8 W         |
| PTO                                                 | 8 W         | 8 W         |
| PSB                                                 | 8 W         | 8 W         |
| PCK                                                 | 8 W         | 8 W         |
| Supplementary Heater: Type of energy input          | Electricity | Electricity |
| Supplementary Heater: PSUP                          | 0.30 kW     | 0.03 kW     |
| Annual energy consumption Qhe                       | 2773 kWh    | 3441 kWh    |

#### EN 12102-1 | Colder Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor  | 36 dB(A)        | 42 dB(A)           |
| Sound power level outdoor | 45 dB(A)        | 45 dB(A)           |

#### EN 14825 | Colder Climate

|                | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| ηs             | 169 %           | 119 %              |
| Prated         | 7.00 kW         | 6.40 kW            |
| SCOP           | 4.31            | 3.17               |
| Tbiv           | -17 °C          | -17 °C             |
| TOL            | -22 °C          | -17 °C             |
| Pdh Tj = -7°C  | 4.38 kW         | 3.98 kW            |
| COP Tj = -7°C  | 3.66            | 2.82               |
| Cdh Tj = -7 °C | 0.990           | 1.000              |
| Pdh Tj = +2°C  | 2.67 kW         | 2.35 kW            |
| COP Tj = +2°C  | 5.22            | 3.63               |
| Cdh Tj = +2 °C | 0.990           | 0.990              |
| Pdh Tj = +7°C  | 2.48 kW         | 2.30 kW            |
| COP Tj = +7°C  | 6.38            | 4.92               |
| Cdh Tj = +7 °C | 0.980           | 0.980              |
| Pdh Tj = 12°C  | 2.72 kW         | 2.70 kW            |
| COP Tj = 12°C  | 6.62            | 6.80               |

|                                                     |             |             |
|-----------------------------------------------------|-------------|-------------|
| Cdh Tj = +12 °C                                     | 0.980       | 0.980       |
| Pdh Tj = Tbiv                                       | 6.15 kW     | 5.59 kW     |
| COP Tj = Tbiv                                       | 2.47        | 1.94        |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 5.51 kW     | 5.59 kW     |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.20        | 1.94        |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000       | 1.000       |
| WTOL                                                | 67 °C       | 67 °C       |
| Poff                                                | 8 W         | 8 W         |
| PTO                                                 | 8 W         | 8 W         |
| PSB                                                 | 8 W         | 8 W         |
| PCK                                                 | 8 W         | 8 W         |
| Supplementary Heater: Type of energy input          | Electricity | Electricity |
| Supplementary Heater: PSUP                          | 1.49 kW     | 6.40 kW     |
| Annual energy consumption Qhe                       | 4003 kWh    | 4984 kWh    |
| Pdh Tj = -15°C (if TOL                              | 5.55        | 5.22        |
| COP Tj = -15°C (if TOL                              | 2.48        | 1.90        |
| Cdh Tj = -15 °C                                     | 1.000       | 1.000       |

#### EN 12102-1 | Warmer Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor  | 36 dB(A)        | 42 dB(A)           |
| Sound power level outdoor | 45 dB(A)        | 45 dB(A)           |

#### EN 14825 | Warmer Climate

|                                                     | Low temperature | Medium temperature |
|-----------------------------------------------------|-----------------|--------------------|
| ηs                                                  | 239 %           | 179 %              |
| Prated                                              | 6.00 kW         | 5.90 kW            |
| SCOP                                                | 6.10            | 4.57               |
| Tbiv                                                | 2 °C            | 2 °C               |
| TOL                                                 | 2 °C            | 2 °C               |
| Pdh Tj = +2°C                                       | 5.68 kW         | 5.58 kW            |
| COP Tj = +2°C                                       | 3.52            | 2.57               |
| Cdh Tj = +2 °C                                      | 1.000           | 1.000              |
| Pdh Tj = +7°C                                       | 4.19 kW         | 3.93 kW            |
| COP Tj = +7°C                                       | 5.85            | 4.03               |
| Cdh Tj = +7 °C                                      | 0.990           | 0.990              |
| Pdh Tj = 12°C                                       | 2.69 kW         | 2.59 kW            |
| COP Tj = 12°C                                       | 6.91            | 5.61               |
| Cdh Tj = +12 °C                                     | 0.980           | 0.980              |
| Pdh Tj = Tbiv                                       | 5.68 kW         | 5.58 kW            |
| COP Tj = Tbiv                                       | 3.52            | 2.57               |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 5.68 kW         | 5.58 kW            |

|                                                                         |             |             |
|-------------------------------------------------------------------------|-------------|-------------|
| COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$       | 3.52        | 2.57        |
| $C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$ | 1.000       | 1.000       |
| WTOL                                                                    | 67 °C       | 67 °C       |
| P <sub>off</sub>                                                        | 8 W         | 8 W         |
| PTO                                                                     | 8 W         | 8 W         |
| PSB                                                                     | 8 W         | 8 W         |
| PCK                                                                     | 8 W         | 8 W         |
| Supplementary Heater: Type of energy input                              | Electricity | Electricity |
| Supplementary Heater: PSUP                                              | 0.32 kW     | 0.32 kW     |
| Annual energy consumption Q <sub>he</sub>                               | 1326 kWh    | 1737 kWh    |

## Model VERSI-O 0209-K1 HT / HK 1F

|                                     |                            |
|-------------------------------------|----------------------------|
| Model name                          | VERSI-O 0209-K1 HT / HK 1F |
| Application                         | Heating (medium temp)      |
| Units                               | Outdoor                    |
| Climate zone (for heating)          | Colder, Warmer             |
| Reversibility                       | Yes                        |
| Cooling mode application (optional) | n/a                        |
| Any additional heat sources         | n/a                        |

## General data

|                  |             |
|------------------|-------------|
| Power supply     | 1x230V 50Hz |
| Off-peak product | n/a         |

## Outdoor Air/Water

### EN 14511-4 | Heating

|                                            |        |
|--------------------------------------------|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure              | passed |
| Defrost test                               | passed |
| Starting and operating test                | passed |

### EN 14511-2 | Heating

|             | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 6.20 kW         | 6.04 kW            |
| El input    | 1.24 kW         | 1.93 kW            |
| COP         | 5.01            | 3.12               |

### EN 12102-1 | Average Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level outdoor | 43 dB(A)        | 44 dB(A)           |

### EN 14825 | Average Climate

|                | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| $\eta_s$       | 191 %           | 138 %              |
| Prated         | 6.40 kW         | 6.00 kW            |
| SCOP           | 4.97            | 3.60               |
| Tbiv           | -10 °C          | -10 °C             |
| TOL            | -10 °C          | -10 °C             |
| Pdh Tj = -7°C  | 5.71 kW         | 5.38 kW            |
| COP Tj = -7°C  | 3.26            | 2.21               |
| Cdh Tj = -7 °C | 1.000           | 1.000              |
| Pdh Tj = +2°C  | 3.74 kW         | 3.51 kW            |
| COP Tj = +2°C  | 5.25            | 3.56               |
| Cdh Tj = +2 °C | 0.990           | 0.990              |
| Pdh Tj = +7°C  | 2.27 kW         | 2.20 kW            |

|                                                     |             |             |
|-----------------------------------------------------|-------------|-------------|
| COP Tj = +7°C                                       | 5.55        | 4.54        |
| Cdh Tj = +7 °C                                      | 0.980       | 0.980       |
| Pdh Tj = 12°C                                       | 2.36 kW     | 2.40 kW     |
| COP Tj = 12°C                                       | 6.65        | 5.85        |
| Cdh Tj = +12 °C                                     | 0.980       | 0.980       |
| Pdh Tj = Tbiv                                       | 6.11 kW     | 5.88 kW     |
| COP Tj = Tbiv                                       | 2.76        | 2.04        |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 6.11 kW     | 5.88 kW     |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.76        | 2.04        |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000       | 1.000       |
| WTOL                                                | 67 °C       | 67 °C       |
| Poff                                                | 8 W         | 8 W         |
| PTO                                                 | 8 W         | 8 W         |
| PSB                                                 | 8 W         | 8 W         |
| PCK                                                 | 8 W         | 8 W         |
| Supplementary Heater: Type of energy input          | Electricity | Electricity |
| Supplementary Heater: PSUP                          | 0.29 kW     | 0.12 kW     |
| Annual energy consumption Qhe                       | 2659 kWh    | 3446 kWh    |

#### EN 12102-1 | Colder Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level outdoor | 43 dB(A)        | 44 dB(A)           |

#### EN 14825 | Colder Climate

|                 | Low temperature | Medium temperature |
|-----------------|-----------------|--------------------|
| ηs              | 166 %           | 117 %              |
| Prated          | 7.00 kW         | 5.80 kW            |
| SCOP            | 4.22            | 3.01               |
| Tbiv            | -17 °C          | -17 °C             |
| TOL             | -22 °C          | -17 °C             |
| Pdh Tj = -7°C   | 4.41 kW         | 3.58 kW            |
| COP Tj = -7°C   | 3.53            | 2.68               |
| Cdh Tj = -7 °C  | 0.990           | 0.990              |
| Pdh Tj = +2°C   | 2.72 kW         | 2.08 kW            |
| COP Tj = +2°C   | 5.09            | 3.34               |
| Cdh Tj = +2 °C  | 0.990           | 0.990              |
| Pdh Tj = +7°C   | 2.12 kW         | 2.02 kW            |
| COP Tj = +7°C   | 5.98            | 4.88               |
| Cdh Tj = +7 °C  | 0.980           | 0.980              |
| Pdh Tj = 12°C   | 2.38 kW         | 2.49 kW            |
| COP Tj = 12°C   | 7.18            | 6.76               |
| Cdh Tj = +12 °C | 0.980           | 0.980              |
| Pdh Tj = Tbiv   | 6.16 kW         | 4.99 kW            |

|                                                     |             |             |
|-----------------------------------------------------|-------------|-------------|
| COP Tj = Tbiv                                       | 2.52        | 1.93        |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 5.06 kW     | 4.99 kW     |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.20        | 1.93        |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000       | 1.000       |
| WTOL                                                | 67 °C       | 67 °C       |
| Poff                                                | 8 W         | 8 W         |
| PTO                                                 | 8 W         | 8 W         |
| PSB                                                 | 8 W         | 8 W         |
| PCK                                                 | 8 W         | 8 W         |
| Supplementary Heater: Type of energy input          | Electricity | Electricity |
| Supplementary Heater: PSUP                          | 1.94 kW     | 5.80 kW     |
| Annual energy consumption Qhe                       | 4090 kWh    | 4759 kWh    |
| Pdh Tj = -15°C (if TOL                              | 5.92        | 4.96        |
| COP Tj = -15°C (if TOL                              | 2.56        | 2.14        |
| Cdh Tj = -15 °C                                     | 1.000       | 1.000       |

#### EN 12102-1 | Warmer Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level outdoor | 43 dB(A)        | 44 dB(A)           |

#### EN 14825 | Warmer Climate

|                                                     | Low temperature | Medium temperature |
|-----------------------------------------------------|-----------------|--------------------|
| $\eta_s$                                            | 238 %           | 163 %              |
| Prated                                              | 6.00 kW         | 6.00 kW            |
| SCOP                                                | 6.08            | 4.17               |
| Tbiv                                                | 2 °C            | 2 °C               |
| TOL                                                 | 2 °C            | 2 °C               |
| Pdh Tj = +2°C                                       | 5.54 kW         | 5.57 kW            |
| COP Tj = +2°C                                       | 3.72            | 2.54               |
| Cdh Tj = +2 °C                                      | 1.000           | 1.000              |
| Pdh Tj = +7°C                                       | 3.95 kW         | 3.95 kW            |
| COP Tj = +7°C                                       | 6.27            | 4.08               |
| Cdh Tj = +7 °C                                      | 0.990           | 0.990              |
| Pdh Tj = 12°C                                       | 2.27 kW         | 2.31 kW            |
| COP Tj = 12°C                                       | 6.40            | 4.59               |
| Cdh Tj = +12 °C                                     | 0.980           | 0.980              |
| Pdh Tj = Tbiv                                       | 5.54 kW         | 5.57 kW            |
| COP Tj = Tbiv                                       | 3.72            | 2.54               |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 5.54 kW         | 5.57 kW            |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 3.72            | 2.54               |

|                                                     |             |             |
|-----------------------------------------------------|-------------|-------------|
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000       | 1.000       |
| WTOL                                                | 67 °C       | 67 °C       |
| Poff                                                | 8 W         | 8 W         |
| PTO                                                 | 8 W         | 8 W         |
| PSB                                                 | 8 W         | 8 W         |
| PCK                                                 | 8 W         | 8 W         |
| Supplementary Heater: Type of energy input          | Electricity | Electricity |
| Supplementary Heater: PSUP                          | 0.46 kW     | 0.43 kW     |
| Annual energy consumption Qhe                       | 1330 kWh    | 1934 kWh    |

## Model VERSI-O 0209-K1 HT / HK 1F + HYDRO C2

|                                     |                                       |
|-------------------------------------|---------------------------------------|
| Model name                          | VERSI-O 0209-K1 HT / HK 1F + HYDRO C2 |
| Application                         | Heating + DHW                         |
| Units                               | Indoor, Outdoor                       |
| Climate zone (for heating)          | Colder, Warmer                        |
| Reversibility                       | Yes                                   |
| Cooling mode application (optional) | n/a                                   |
| Any additional heat sources         | n/a                                   |

### General data

|                  |             |
|------------------|-------------|
| Power supply     | 1x230V 50Hz |
| Off-peak product | n/a         |

### Outdoor Air/Water

#### EN 16147 | Average Climate

|                                 |            |
|---------------------------------|------------|
| Declared load profile           | L          |
| Efficiency $\eta_{DHW}$         | 97 %       |
| COP                             | 2.30       |
| Heating up time                 | 2:35 h:min |
| Standby power input             | 47.4 W     |
| Reference hot water temperature | 54.5 °C    |
| Mixed water at 40°C             | 264 l      |

#### EN 14511-4 | Heating

|                                            |        |
|--------------------------------------------|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure              | passed |
| Defrost test                               | passed |
| Starting and operating test                | passed |

#### EN 14511-2 | Heating

|             | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 6.04 kW         |                    |
| El input    | 1.93 kW         |                    |
| COP         | 3.12            |                    |

#### EN 12102-1 | Average Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor  | 0 dB(A)         |                    |
| Sound power level outdoor | 44 dB(A)        |                    |

#### EN 14825 | Average Climate

|          | Low temperature | Medium temperature |
|----------|-----------------|--------------------|
| $\eta_s$ | 138 %           |                    |
| Prated   | 6.00 kW         |                    |

|                                                     |             |
|-----------------------------------------------------|-------------|
| SCOP                                                | 3.60        |
| Tbiv                                                | -10 °C      |
| TOL                                                 | -10 °C      |
| Pdh Tj = -7°C                                       | 5.38 kW     |
| COP Tj = -7°C                                       | 2.21        |
| Cdh Tj = -7 °C                                      | 1.000       |
| Pdh Tj = +2°C                                       | 3.51 kW     |
| COP Tj = +2°C                                       | 3.56        |
| Cdh Tj = +2 °C                                      | 0.990       |
| Pdh Tj = +7°C                                       | 2.20 kW     |
| COP Tj = +7°C                                       | 4.54        |
| Cdh Tj = +7 °C                                      | 0.980       |
| Pdh Tj = 12°C                                       | 2.40 kW     |
| COP Tj = 12°C                                       | 5.85        |
| Cdh Tj = +12 °C                                     | 0.980       |
| Pdh Tj = Tbiv                                       | 5.88 kW     |
| COP Tj = Tbiv                                       | 2.04        |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 5.88 kW     |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.04        |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000       |
| WTOL                                                | 67 °C       |
| Poff                                                | 8 W         |
| PTO                                                 | 8 W         |
| PSB                                                 | 8 W         |
| PCK                                                 | 8 W         |
| Supplementary Heater: Type of energy input          | Electricity |
| Supplementary Heater: PSUP                          | 0.12 kW     |
| Annual energy consumption Qhe                       | 3446 kWh    |

#### EN 12102-1 | Colder Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor  | 0 dB(A)         |                    |
| Sound power level outdoor | 44 dB(A)        |                    |

#### EN 14825 | Colder Climate

|               | Low temperature | Medium temperature |
|---------------|-----------------|--------------------|
| $\eta_s$      | 117 %           |                    |
| Prated        | 5.80 kW         |                    |
| SCOP          | 3.01            |                    |
| Tbiv          | -17 °C          |                    |
| TOL           | -17 °C          |                    |
| Pdh Tj = -7°C | 3.58 kW         |                    |
| COP Tj = -7°C | 2.68            |                    |

|                                                     |             |
|-----------------------------------------------------|-------------|
| Cdh Tj = -7 °C                                      | 0.990       |
| Pdh Tj = +2°C                                       | 2.08 kW     |
| COP Tj = +2°C                                       | 3.34        |
| Cdh Tj = +2 °C                                      | 0.990       |
| Pdh Tj = +7°C                                       | 2.02 kW     |
| COP Tj = +7°C                                       | 4.88        |
| Cdh Tj = +7 °C                                      | 0.980       |
| Pdh Tj = 12°C                                       | 2.49 kW     |
| COP Tj = 12°C                                       | 6.76        |
| Cdh Tj = +12 °C                                     | 0.980       |
| Pdh Tj = Tbiv                                       | 4.99 kW     |
| COP Tj = Tbiv                                       | 1.93        |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 4.99 kW     |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 1.93        |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000       |
| WTOL                                                | 67 °C       |
| Poff                                                | 8 W         |
| PTO                                                 | 8 W         |
| PSB                                                 | 8 W         |
| PCK                                                 | 8 W         |
| Supplementary Heater: Type of energy input          | Electricity |
| Supplementary Heater: PSUP                          | 5.80 kW     |
| Annual energy consumption Qhe                       | 4759 kWh    |
| Pdh Tj = -15°C (if TOL                              | 4.96        |
| COP Tj = -15°C (if TOL                              | 2.14        |
| Cdh Tj = -15 °C                                     | 1.000       |

#### EN 12102-1 | Warmer Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor  | 0 dB(A)         |                    |
| Sound power level outdoor | 44 dB(A)        |                    |

#### EN 14825 | Warmer Climate

|                | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| ηs             | 163 %           |                    |
| Prated         | 6.00 kW         |                    |
| SCOP           | 4.17            |                    |
| Tbiv           | 2 °C            |                    |
| TOL            | 2 °C            |                    |
| Pdh Tj = +2°C  | 5.57 kW         |                    |
| COP Tj = +2°C  | 2.54            |                    |
| Cdh Tj = +2 °C | 1.000           |                    |
| Pdh Tj = +7°C  | 3.95 kW         |                    |

|                                                     |             |
|-----------------------------------------------------|-------------|
| COP Tj = +7°C                                       | 4.08        |
| Cdh Tj = +7 °C                                      | 0.990       |
| Pdh Tj = 12°C                                       | 2.31 kW     |
| COP Tj = 12°C                                       | 4.59        |
| Cdh Tj = +12 °C                                     | 0.980       |
| Pdh Tj = Tbiv                                       | 5.57 kW     |
| COP Tj = Tbiv                                       | 2.54        |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 5.57 kW     |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.54        |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000       |
| WTOL                                                | 67 °C       |
| Poff                                                | 8 W         |
| PTO                                                 | 8 W         |
| PSB                                                 | 8 W         |
| PCK                                                 | 8 W         |
| Supplementary Heater: Type of energy input          | Electricity |
| Supplementary Heater: PSUP                          | 0.43 kW     |
| Annual energy consumption Qhe                       | 1934 kWh    |

## Model VERSI-X 0209-K1 HT / HK 1F + HYDRO C2

|                                     |                                       |
|-------------------------------------|---------------------------------------|
| Model name                          | VERSI-X 0209-K1 HT / HK 1F + HYDRO C2 |
| Application                         | Heating + DHW                         |
| Units                               | Indoor, Outdoor                       |
| Climate zone (for heating)          | Colder, Warmer                        |
| Reversibility                       | Yes                                   |
| Cooling mode application (optional) | n/a                                   |
| Any additional heat sources         | n/a                                   |

### General data

|                  |             |
|------------------|-------------|
| Power supply     | 1x230V 50Hz |
| Off-peak product | n/a         |

### Outdoor Air/Water

#### EN 16147 | Average Climate

|                                 |            |
|---------------------------------|------------|
| Declared load profile           | L          |
| Efficiency $\eta_{DHW}$         | 96 %       |
| COP                             | 2.30       |
| Heating up time                 | 2:18 h:min |
| Standby power input             | 41.0 W     |
| Reference hot water temperature | 54.4 °C    |
| Mixed water at 40°C             | 255 l      |

#### EN 14511-4 | Heating

|                                            |        |
|--------------------------------------------|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure              | passed |
| Defrost test                               | passed |
| Starting and operating test                | passed |

#### EN 14511-2 | Heating

|             | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 6.09 kW         |                    |
| El input    | 1.95 kW         |                    |
| COP         | 3.13            |                    |

#### EN 12102-1 | Average Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor  | 42 dB(A)        |                    |
| Sound power level outdoor | 45 dB(A)        |                    |

#### EN 14825 | Average Climate

|          | Low temperature | Medium temperature |
|----------|-----------------|--------------------|
| $\eta_s$ | 141 %           |                    |
| Prated   | 6.10 kW         |                    |

|                                                     |             |
|-----------------------------------------------------|-------------|
| SCOP                                                | 3.66        |
| Tbiv                                                | -10 °C      |
| TOL                                                 | -10 °C      |
| Pdh Tj = -7°C                                       | 5.46 kW     |
| COP Tj = -7°C                                       | 2.32        |
| Cdh Tj = -7 °C                                      | 1.000       |
| Pdh Tj = +2°C                                       | 3.30 kW     |
| COP Tj = +2°C                                       | 3.71        |
| Cdh Tj = +2 °C                                      | 0.990       |
| Pdh Tj = +7°C                                       | 2.20 kW     |
| COP Tj = +7°C                                       | 4.30        |
| Cdh Tj = +7 °C                                      | 0.980       |
| Pdh Tj = 12°C                                       | 2.53 kW     |
| COP Tj = 12°C                                       | 5.82        |
| Cdh Tj = +12 °C                                     | 0.980       |
| Pdh Tj = Tbiv                                       | 6.07 kW     |
| COP Tj = Tbiv                                       | 2.16        |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 6.07 kW     |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.16        |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000       |
| WTOL                                                | 67 °C       |
| Poff                                                | 8 W         |
| PTO                                                 | 8 W         |
| PSB                                                 | 8 W         |
| PCK                                                 | 8 W         |
| Supplementary Heater: Type of energy input          | Electricity |
| Supplementary Heater: PSUP                          | 0.03 kW     |
| Annual energy consumption Qhe                       | 3441 kWh    |

#### EN 12102-1 | Colder Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor  | 42 dB(A)        |                    |
| Sound power level outdoor | 45 dB(A)        |                    |

#### EN 14825 | Colder Climate

|               | Low temperature | Medium temperature |
|---------------|-----------------|--------------------|
| $\eta_s$      | 119 %           |                    |
| Prated        | 6.40 kW         |                    |
| SCOP          | 3.17            |                    |
| Tbiv          | -17 °C          |                    |
| TOL           | -17 °C          |                    |
| Pdh Tj = -7°C | 3.98 kW         |                    |
| COP Tj = -7°C | 2.82            |                    |

|                                                     |             |
|-----------------------------------------------------|-------------|
| Cdh Tj = -7 °C                                      | 1.000       |
| Pdh Tj = +2°C                                       | 2.35 kW     |
| COP Tj = +2°C                                       | 3.63        |
| Cdh Tj = +2 °C                                      | 0.990       |
| Pdh Tj = +7°C                                       | 2.30 kW     |
| COP Tj = +7°C                                       | 4.92        |
| Cdh Tj = +7 °C                                      | 0.980       |
| Pdh Tj = 12°C                                       | 2.70 kW     |
| COP Tj = 12°C                                       | 6.80        |
| Cdh Tj = +12 °C                                     | 0.980       |
| Pdh Tj = Tbiv                                       | 5.59 kW     |
| COP Tj = Tbiv                                       | 1.94        |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 5.59 kW     |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 1.94        |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000       |
| WTOL                                                | 67 °C       |
| Poff                                                | 8 W         |
| PTO                                                 | 8 W         |
| PSB                                                 | 8 W         |
| PCK                                                 | 8 W         |
| Supplementary Heater: Type of energy input          | Electricity |
| Supplementary Heater: PSUP                          | 6.40 kW     |
| Annual energy consumption Qhe                       | 4984 kWh    |
| Pdh Tj = -15°C (if TOL                              | 5.22        |
| COP Tj = -15°C (if TOL                              | 1.90        |
| Cdh Tj = -15 °C                                     | 1.000       |

#### EN 12102-1 | Warmer Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor  | 42 dB(A)        |                    |
| Sound power level outdoor | 45 dB(A)        |                    |

#### EN 14825 | Warmer Climate

|                | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| ηs             | 179 %           |                    |
| Prated         | 5.90 kW         |                    |
| SCOP           | 4.57            |                    |
| Tbiv           | 2 °C            |                    |
| TOL            | 2 °C            |                    |
| Pdh Tj = +2°C  | 5.58 kW         |                    |
| COP Tj = +2°C  | 2.57            |                    |
| Cdh Tj = +2 °C | 1.000           |                    |
| Pdh Tj = +7°C  | 3.93 kW         |                    |

|                                                     |             |
|-----------------------------------------------------|-------------|
| COP Tj = +7°C                                       | 4.03        |
| Cdh Tj = +7 °C                                      | 0.990       |
| Pdh Tj = 12°C                                       | 2.59 kW     |
| COP Tj = 12°C                                       | 5.61        |
| Cdh Tj = +12 °C                                     | 0.980       |
| Pdh Tj = Tbiv                                       | 5.58 kW     |
| COP Tj = Tbiv                                       | 2.57        |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 5.58 kW     |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.57        |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000       |
| WTOL                                                | 67 °C       |
| Poff                                                | 8 W         |
| PTO                                                 | 8 W         |
| PSB                                                 | 8 W         |
| PCK                                                 | 8 W         |
| Supplementary Heater: Type of energy input          | Electricity |
| Supplementary Heater: PSUP                          | 0.32 kW     |
| Annual energy consumption Qhe                       | 1737 kWh    |

## Model VERSI-I 0209-K1 HT / HK UF E + HR200

|                                     |                                      |
|-------------------------------------|--------------------------------------|
| Model name                          | VERSI-I 0209-K1 HT / HK UF E + HR200 |
| Application                         | Heating + DHW                        |
| Units                               | Indoor, Outdoor                      |
| Climate zone (for heating)          | Colder, Warmer                       |
| Reversibility                       | Yes                                  |
| Cooling mode application (optional) | n/a                                  |
| Any additional heat sources         | n/a                                  |

## General data

|                  |             |
|------------------|-------------|
| Power supply     | 1x230V 50Hz |
| Off-peak product | n/a         |

## Outdoor Air/Water

### EN 16147 | Average Climate

|                                 |            |
|---------------------------------|------------|
| Declared load profile           | L          |
| Efficiency $\eta_{DHW}$         | 100 %      |
| COP                             | 2.38       |
| Heating up time                 | 2:27 h:min |
| Standby power input             | 44.9 W     |
| Reference hot water temperature | 54.9 °C    |
| Mixed water at 40°C             | 282 l      |

### EN 14511-4 | Heating

|                                            |        |
|--------------------------------------------|--------|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure              | passed |
| Defrost test                               | passed |
| Starting and operating test                | passed |

### EN 14511-2 | Heating

|             | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 6.09 kW         |                    |
| El input    | 1.95 kW         |                    |
| COP         | 3.13            |                    |

### EN 12102-1 | Average Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor  | 42 dB(A)        |                    |
| Sound power level outdoor | 45 dB(A)        |                    |

### EN 14825 | Average Climate

|          | Low temperature | Medium temperature |
|----------|-----------------|--------------------|
| $\eta_s$ | 141 %           |                    |
| Prated   | 6.10 kW         |                    |

|                                                     |             |
|-----------------------------------------------------|-------------|
| SCOP                                                | 3.66        |
| Tbiv                                                | -10 °C      |
| TOL                                                 | -10 °C      |
| Pdh Tj = -7°C                                       | 5.46 kW     |
| COP Tj = -7°C                                       | 2.32        |
| Cdh Tj = -7 °C                                      | 1.000       |
| Pdh Tj = +2°C                                       | 3.30 kW     |
| COP Tj = +2°C                                       | 3.71        |
| Cdh Tj = +2 °C                                      | 0.990       |
| Pdh Tj = +7°C                                       | 2.20 kW     |
| COP Tj = +7°C                                       | 4.30        |
| Cdh Tj = +7 °C                                      | 0.980       |
| Pdh Tj = 12°C                                       | 2.53 kW     |
| COP Tj = 12°C                                       | 5.82        |
| Cdh Tj = +12 °C                                     | 0.980       |
| Pdh Tj = Tbiv                                       | 6.07 kW     |
| COP Tj = Tbiv                                       | 2.16        |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 6.07 kW     |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.16        |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000       |
| WTOL                                                | 67 °C       |
| Poff                                                | 8 W         |
| PTO                                                 | 8 W         |
| PSB                                                 | 8 W         |
| PCK                                                 | 8 W         |
| Supplementary Heater: Type of energy input          | Electricity |
| Supplementary Heater: PSUP                          | 0.03 kW     |
| Annual energy consumption Qhe                       | 3441 kWh    |

### EN 12102-1 | Colder Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor  | 42 dB(A)        |                    |
| Sound power level outdoor | 45 dB(A)        |                    |

### EN 14825 | Colder Climate

|               | Low temperature | Medium temperature |
|---------------|-----------------|--------------------|
| $\eta_s$      | 119 %           |                    |
| Prated        | 6.40 kW         |                    |
| SCOP          | 3.17            |                    |
| Tbiv          | -17 °C          |                    |
| TOL           | -17 °C          |                    |
| Pdh Tj = -7°C | 3.98 kW         |                    |
| COP Tj = -7°C | 2.82            |                    |

|                                                     |             |
|-----------------------------------------------------|-------------|
| Cdh Tj = -7 °C                                      | 1.000       |
| Pdh Tj = +2°C                                       | 2.35 kW     |
| COP Tj = +2°C                                       | 3.63        |
| Cdh Tj = +2 °C                                      | 0.990       |
| Pdh Tj = +7°C                                       | 2.30 kW     |
| COP Tj = +7°C                                       | 4.92        |
| Cdh Tj = +7 °C                                      | 0.980       |
| Pdh Tj = 12°C                                       | 2.70 kW     |
| COP Tj = 12°C                                       | 6.80        |
| Cdh Tj = +12 °C                                     | 0.980       |
| Pdh Tj = Tbiv                                       | 5.59 kW     |
| COP Tj = Tbiv                                       | 1.94        |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 5.59 kW     |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 1.94        |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000       |
| WTOL                                                | 67 °C       |
| Poff                                                | 8 W         |
| PTO                                                 | 8 W         |
| PSB                                                 | 8 W         |
| PCK                                                 | 8 W         |
| Supplementary Heater: Type of energy input          | Electricity |
| Supplementary Heater: PSUP                          | 6.40 kW     |
| Annual energy consumption Qhe                       | 4984 kWh    |
| Pdh Tj = -15°C (if TOL                              | 5.22        |
| COP Tj = -15°C (if TOL                              | 1.90        |
| Cdh Tj = -15 °C                                     | 1.000       |

#### EN 12102-1 | Warmer Climate

|                           | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor  | 42 dB(A)        |                    |
| Sound power level outdoor | 45 dB(A)        |                    |

#### EN 14825 | Warmer Climate

|                | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| ηs             | 179 %           |                    |
| Prated         | 5.90 kW         |                    |
| SCOP           | 4.57            |                    |
| Tbiv           | 2 °C            |                    |
| TOL            | 2 °C            |                    |
| Pdh Tj = +2°C  | 5.58 kW         |                    |
| COP Tj = +2°C  | 2.57            |                    |
| Cdh Tj = +2 °C | 1.000           |                    |
| Pdh Tj = +7°C  | 3.93 kW         |                    |

|                                                     |             |
|-----------------------------------------------------|-------------|
| COP Tj = +7°C                                       | 4.03        |
| Cdh Tj = +7 °C                                      | 0.990       |
| Pdh Tj = 12°C                                       | 2.59 kW     |
| COP Tj = 12°C                                       | 5.61        |
| Cdh Tj = +12 °C                                     | 0.980       |
| Pdh Tj = Tbiv                                       | 5.58 kW     |
| COP Tj = Tbiv                                       | 2.57        |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 5.58 kW     |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.57        |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000       |
| WTOL                                                | 67 °C       |
| Poff                                                | 8 W         |
| PTO                                                 | 8 W         |
| PSB                                                 | 8 W         |
| PCK                                                 | 8 W         |
| Supplementary Heater: Type of energy input          | Electricity |
| Supplementary Heater: PSUP                          | 0.32 kW     |
| Annual energy consumption Qhe                       | 1737 kWh    |