

Subtype Volan 12

Certificate Holder	THERMAGEN sp. z o.o.
Address	Ul. Warszawska 50
ZIP	82-100
City	Nowy Dwór Gdański
Country	PL
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Volan 12
Registration number	011-1W0532
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	0.85 kg
Certification Date	01.06.2022
Testing basis	European KEYMARK Scheme for Heat Pumps Rev. 9 (as of 2021-03)

Model Volan 12 400V

Model name	Volan 12 400V
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	5.30 kW	4.60 kW
El input	1.11 kW	1.60 kW
COP	4.80	2.90

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	154 %	125 %
Prated	6.50 kW	6.50 kW
SCOP	3.93	3.21
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.76 kW	5.76 kW
COP Tj = -7°C	2.72	2.02
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	3.55 kW	3.56 kW
COP Tj = +2°C	4.25	3.20
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	2.31 kW	2.31 kW

COP Tj = +7°C	4.53	4.24
Cdh Tj = +7 °C	0.980	0.980
Pdh Tj = 12°C	2.52 kW	2.56 kW
COP Tj = 12°C	4.26	4.50
Cdh Tj = +12 °C	0.980	0.980
Pdh Tj = Tbiv	5.76 kW	5.76 kW
COP Tj = Tbiv	2.72	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.68 kW	5.65 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.58	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.82 kW	0.85 kW
Annual energy consumption Qhe	3418 kWh	4190 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	136 %	113 %
Prated	6.60 kW	6.60 kW
SCOP	3.47	2.89
Tbiv	-12 °C	-12 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	4.06 kW	4.05 kW
COP Tj = -7°C	3.52	2.55
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	2.47 kW	2.41 kW
COP Tj = +2°C	4.48	3.70
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.32 kW	2.32 kW
COP Tj = +7°C	4.50	4.46
Cdh Tj = +7 °C	0.980	0.980
Pdh Tj = 12°C	2.54 kW	2.57 kW
COP Tj = 12°C	4.28	4.48
Cdh Tj = +12 °C	0.980	0.980
Pdh Tj = Tbiv	4.86 kW	4.86 kW

COP Tj = Tbiv	2.74	2.09
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.04 kW	4.98 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.64	2.04
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.60 kW	6.60 kW
Annual energy consumption Qhe	4692 kWh	5628 kWh
Pdh Tj = -15°C (if TOL	5.04	4.98
COP Tj = -15°C (if TOL	2.64	2.04
Cdh Tj = -15 °C	1.000	1.000

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	175 %	150 %
Prated	6.30 kW	6.10 kW
SCOP	4.45	3.82
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.32 kW	6.13 kW
COP Tj = +2°C	2.62	1.90
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.37 kW	4.03 kW
COP Tj = +7°C	5.34	3.80
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	2.57 kW	2.61 kW
COP Tj = 12°C	4.41	4.51
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	6.32 kW	6.13 kW
COP Tj = Tbiv	2.62	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.32 kW	6.13 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.90
WTOL	70 °C	70 °C

Poff	0 W	0 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1890 kWh	2133 kWh

Model Volan 12

Model name	Volan 12
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	5.30 kW	4.60 kW
El input	1.11 kW	1.60 kW
COP	4.80	2.90

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	154 %	125 %
Prated	6.50 kW	6.50 kW
SCOP	3.93	3.21
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.76 kW	5.76 kW
COP Tj = -7°C	2.72	2.02
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	3.55 kW	3.56 kW
COP Tj = +2°C	4.25	3.20
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	2.31 kW	2.31 kW

COP Tj = +7°C	4.53	4.24
Cdh Tj = +7 °C	0.980	0.980
Pdh Tj = 12°C	2.52 kW	2.31 kW
COP Tj = 12°C	4.26	4.24
Cdh Tj = +12 °C	0.980	0.980
Pdh Tj = Tbiv	5.76 kW	5.76 kW
COP Tj = Tbiv	2.72	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.68 kW	5.65 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.58	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.82 kW	0.85 kW
Annual energy consumption Qhe	3418 kWh	4190 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	136 %	113 %
Prated	6.60 kW	6.60 kW
SCOP	3.47	2.89
Tbiv	-12 °C	-12 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	4.06 kW	4.05 kW
COP Tj = -7°C	3.52	2.55
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	2.47 kW	2.41 kW
COP Tj = +2°C	4.48	3.70
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.32 kW	2.32 kW
COP Tj = +7°C	4.50	4.46
Cdh Tj = +7 °C	0.980	0.980
Pdh Tj = 12°C	2.54 kW	2.57 kW
COP Tj = 12°C	4.28	4.48
Cdh Tj = +12 °C	0.980	0.980
Pdh Tj = Tbiv	4.86 kW	4.86 kW

COP Tj = Tbiv	2.74	2.09
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.04 kW	4.98 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.64	2.04
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.60 kW	6.60 kW
Annual energy consumption Qhe	4692 kWh	5628 kWh
Pdh Tj = -15°C (if TOL	5.04	4.98
COP Tj = -15°C (if TOL	2.64	2.04
Cdh Tj = -15 °C	1.000	1.000

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	175 %	150 %
Prated	6.30 kW	6.10 kW
SCOP	4.45	3.82
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.32 kW	6.13 kW
COP Tj = +2°C	2.62	1.90
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.37 kW	4.03 kW
COP Tj = +7°C	5.34	3.80
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	2.57 kW	2.61 kW
COP Tj = 12°C	4.41	4.51
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	6.32 kW	6.13 kW
COP Tj = Tbiv	2.62	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.32 kW	6.13 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.90
WTOL	70 °C	70 °C

Poff	0 W	0 W
PTO	10 W	10 W
PSB	8 W	8 W
PCK	10 W	10 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1890 kWh	2133 kWh