

| Certificate Holder | Zhongshan Amitime Electric Co., Ltd |
|---------------------|---|
| Address | 5th Yandong Rd |
| ZIP | |
| City | Zhongshan City - Guangdong |
| Country | CN |
| Certification Body | BRE Global Limited |
| Subtype title | DC Inverter Air to Water Heat Pump Unit-R32-XC 09 |
| Registration number | 041-K027-02 |
| Heat Pump Type | Outdoor Air/Water |
| Refrigerant | R32 |
| Mass of Refrigerant | 1.15 kg |
| Certification Date | 27.06.2022 |
| Testing basis | Heat Pump Keymark Scheme Rules Rev 09 |



| Model PAVH-09V1FXC | | |
|--|-----------------------|--------------------|
| Model name | PAVH-09V1FXC | |
| Application | Heating (medium temp) | |
| Units | Outdoor | |
| Climate zone (for heating) | n/a | |
| Reversibility | Yes | |
| Cooling mode application (optional) | n/a | |
| Any additional heat sources | n/a | |
| General data | | |
| Power supply | 1x230V 50Hz | |
| Off-peak product | n/a | |
| | | |
| Outdoor Air/Water | | |
| EN 14511-4 Heating | | |
| Shutting off the heat transfer medium flow | passed | |
| Complete power supply failure | passed | |
| Defrost test | passed | |
| Starting and operating test | passed | |
| EN 12102-1 Average Climate | | |
| | Low temperature | Medium temperature |
| Sound power level outdoor | 64 dB(A) | 67 dB(A) |
| | | |
| EN 14825 Average Climate | | |
| | Low temperature | Medium temperature |
| ης | 178 % | 129 % |
| Prated | 8.49 kW | 7.45 kW |
| SCOP | 4.53 | 3.29 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7 °C | 7.51 kW | 6.59 kW |
| $COP Tj = -7^{\circ}C$ | 2.99 | 1.93 |
| Cdh Tj = -7 °C | 0.900 | 0.900 |
| Pdh Tj = $+2$ °C | 4.60 kW | 4.13 kW |
| $COP Tj = +2^{\circ}C$ | 4.44 | 3.35 |
| Cdh Tj = +2 °C | 0.900 | 0.900 |
| Pdh Tj = $+7^{\circ}$ C | 4.59 kW | 4.32 kW |
| $COP Tj = +7^{\circ}C$ | 6.27 | 4.64 |
| Cdh Tj = +7 °C | 0.900 | 0.900 |
| Pdh Tj = 12°C | 5.20 kW | 5.14 kW |
| COP Tj = 12°C | 8.10 | 6.24 |
| Cdh Tj = +12 °C | 0.000 | 0.000 |
| • | 0.900 | 0.900 |
| Pdh Tj = Tbiv COP Tj = Tbiv | 7.51 kW 2.99 | 6.59 kW 1.93 |



| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 6.90 kW | 6.24 kW |
|---|-------------|-------------|
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.76 | 1.68 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.900 | 0.900 |
| WTOL | 58 °C | 58 °C |
| Poff | 8 W | 8 W |
| PTO | 32 W | 32 W |
| PSB | 8 W | 8 W |
| PCK | 41 W | 41 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 1.59 kW | 1.22 kW |
| Annual energy consumption Qhe | 3874 kWh | 4675 kWh |
| | | |