

CERTIFICATE HEAT PUMP KEYMARK 012-C700122

Loria 6006 R32 Outdoor air/Water heat pump

Issued to

Groupe Atlantic

Rue des Fondeurs BP64, FR-59660 Merville Organisation number: FR87 440 555 886 Phone: +33 (0) 3 28 50 21 00, Fax: +33 (0) 3 28 50 21 90 E-mail: <u>Atl Certif APCdom@groupe-atlantic.com.</u>, Web: <u>www.atlantic.fr</u>

and produced in the manufacturing site 59660 Merville, France and 20230 Chonburi Thailand

Product description

Product, type: Outdoor air/Water heat pumps Subtype: Loria 6006 R32 Models: Loria 6006 R32, Loria Duo 6006 R32, Loria Duo 6006 2C R32 the Duo models has certified DHW performance.

Testing basis and miscellaneous

The products have been tested in accordance with EN 14511:2018, EN 14825:2018, EN 12102:2017, EN 16147:2017 and KEYMARK Certification Scheme for Heat Pumps (2019). Other terms and conditions are set out in RISE Certification rules for Heat Pump KEYMARK Scheme, SPCR 404.

Mark of conformity and right of use

This certificate entitles the holder to use the mark of conformity shown below in conjunction with the specified registration number.



Validity

This certificate is valid until not later than 2031-09-07. To check the validity of this certificate, please visit <u>www.ri.se</u>. For detailed information about this product please visit the <u>Heat Pump</u> <u>KEYMARK database</u>.

Stefan Coric

Certificate No. 012-C700122 | issue 1 | 2021-09-08

RISE Research Institutes of Sweden AB | Certification

Box 857, SE-50115 Borås, Sweden

<u> +46 10 516 </u>50 00 | certifiering@ri.se | www.ri.se

